



--- ADDENDUM #1 ---

Issued November 19, 2024 to all bidders

To be added to and made part of the Tender Documents

1.0 Intent

- .1 This addendum is issued prior to closing of bids to provide revisions to the tender documents.
- .2 Such revisions shall form part of the Tender Documents and change the original Tender Documents only in the manner and to the extent stated. **A signed copy of this addendum must be attached to the Bid and the Bidder must acknowledge receipt of this addendum in the space provided.**
- .3 The statements below are for clarification purposes in response to questions received from bidders.

2.0 Directive

- .1 Bidders are instructed to carry pricing for air quality sampling in **six (6) locations within Town Hall, and three (3) locations within the Library, plus any required reference sampling.** Simultaneous sampling is not required, however collection must occur at times of peak (or representative) occupancy of the spaces. Actual sampling locations and times to be coordinated with staff.
- .2 Disregard any prior correspondence or email responses regarding number of samples required, and refer to the above.

Kind regards,

A handwritten signature in black ink that reads "Alex de Sousa".

Alexander J. de Sousa, P.Eng.
Director of Engineering & Public Works
Town of Wolfville

Representative Signature

Company

Date

-----END OF ADDENDUM #1-----

Returned signed acknowledgement with bid submission.